

EU DECLARATION OF CONFORMITY

Issued in accordance with Act 102/2001 Coll. And ČSN EN ISO/IEC 17050-1:2011
č.11/FIPRON STICKER/2023-001

Manufacturer:

FIRESI s.r.o. IČO: 29188024
Lidická kolonie 1108/47, 586 01 Jihlava, Czech Republic

Autonomous fire prevention system with thermally activated extinguishing agent in
microcapsules FIPRON STICKER P, 15

Technical data identifying the product:

Type of product		P	15	
Dimensions (diameter) mm		30x30x2	85x45x2	
Weight g		2,6±0,2	10±1,5	
PRODUCT CONSTRUCTION	Self-adhesive tape			
Scope of use	Extinguishing electrical equipment in limited volumes			
Groups of fires (according to EN 2)		A	A,B	
Activation temperature , C	120±10 °C			
Maximum time to the disappearance of flame combustion (s)		60	120	
Declared time without burn-back (min.) (confirmed by tests)		300	180	
Maximum volume protected by 1 meter of cord (dm ³)		0,2 dm ³	0,2 dm ³	
Range of operating temperatures	From -60 to +80 °C			
REACH classification of extinguishing suitability for use	2171; CAS: 677-69-0, EINECS: 211-634-3 227ea+2171I, CAS:677-69-0, EINECS: 211-634-1, CAS: 431-89-0, EINECS: 207-079-2			
Declared minimum period of products suitability for use	60 months			

The N1 type certification system was used when assessing compliance, which includes elements according to ČSN EN ISO/IEC 17067:2014 and ČSN EN 15004-2:2009

1. Selection (normative document, sampling);
2. Determination of characteristics by product testing and assessment of production conditions;
3. Review of obtained evidence of conformity;
4. Decision on certification;
5. Issuing certificate of conformity, granting right for use;

6. Supervision according to:

- evaluation of the production process,
 - review and analysis of customers complaint information submitted by manufacturers and assessment of corrective and preventive measures taken.
7. ISO9001:2016 certificate number 9001/02/19 rev. 1, issued by DOS, subject of certification: Production of autonomous fire extinguishing system FIPRON.
8. Type certificate issued by AO 221 Ministry of the Interior of the Czech Republic, TUPO number 221/026/2023.

Jihlava: 04.07.2023

A handwritten signature in blue ink is written over a circular stamp. The stamp contains the Firesi logo and the following text: "FIRESI s.r.o.", "Lidická kolonie 1108/47, 506 01 Jihlava", and "IČ: 29188024, DIČ: CZ:29188024".

Firesi
FIRESI s.r.o. 
Lidická kolonie 1108/47, 506 01 Jihlava
IČ: 29188024, DIČ: CZ:29188024

.....
František Klika
Firesi s.r.o. CEO